

The
VIRTUAL MUSEUM
of the
LANCASHIRE & YORKSHIRE RAILWAY

Operational Documents & Pamphlets

January 1888

Inspectors Report as to Fire Apparatus,
Bury Station.

(1 Page).

Lancashire and Yorkshire Railway.

INSPECTOR'S REPORT AS TO FIRE APPARATUS

BURY STATION, Jan 30th 1888

R/30.1

REMARKS

Mr Lord

Wardleworth

Dear Sir

Referring to your note of Jan'y 28th respecting 'Turtington' having laid down a delivery pipe in the yard so as to allow a cart to pass over it. - I consider this gross negligence, & in taking a delivery pipe off, he ought to have put it aside, out of the way, before wrapping up his hose. If this matter were reported to Headquarters, he would certainly be charged for it; and, I may say, that the delivery pipe has been roughly used at the connection, in addition to the cart running over it, & I feel certain that more care wants taking in the use of your appliances, than has been the case, in accordance with the appearance of this pipe; & further, you had no need to send the delivery pipe to me, as I do not repair them. You should have sent it to the Stores Dept, accompanied with a repair note, & advised me of its being sent away. Send a repair note at once to General Stores. I have forwarded it to Mr Prentis for repairs. - Please note. - Yours truly

Wm Carter.